



1900 SW 44th Ave.
Ocala, Fl. 34474

November 2, 2010

To Whom It May Concern:

We tested our PVC Single Hung window, SH-8100, with three glazing options for STC ratings. The results are below:

Glazing 1:

7/8" IG, consisting of 1/8" glass, 5/8" air space, 1/8" glass obtained an STC of 27.

Glazing 2:

7/8" IG, consisting of 1/8" glass, 3/8" air space, 5/16" laminated glass (1/8" – 0.090 PVB – 1/8") obtained an STC of 32.

Glazing 3:

7/8" IG, consisting of 3/16" laminated glass (3/32" – 0.030 PVB – 3/32"), 1/4" air space, 5/16" laminated glass (1/8" – 0.090 PVB – 1/8") obtained an STC of 33

Glazing 1 is our standard Non-Impact glazing. Glazing 2.is our standard Impact glazing.

If you need any additional information, do not hesitate to contact me.

Sincerely,

Michael LaFevre
V.P. Engineering
Custom Window Systems, Inc.
Ph# 352-368-6922 Ext. 207
Email: mlafevre@cws.cc